CENTEXBEL

BEAULIEU REAL NV
Groene Dreef 15A
9770 KRUISHOUTEM
BELGIË

Your notice of	Your reference	our reference	date
		PW/10774	2008-11-25

Certification Report Nr. 08/10774

1. Description of the flooring:

Product group:	Needlefelt tiles - FR 100% polypropylene Partly impregnated SBR latex AF + bitumen backing
Total mass:	3510 g/m² - 5430 g/m²
Effective pile thickness:	7.0 mm – 9.3 mm

2. Executed tests:

European Fire classification in accordance with EN 13501-1 (2002)		
Class	EN ISO 11925-2 (15 s surface flame attack) or EN 14041 (2004)	EN ISO 9239-1 (test duration = 30 min)
B_{fl}	E_{fl}	heat flux ≥ 8,0 kW/m²

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

loose laid tested on a non-combustible substrate

B_{fl} - s1

This certification report runs to 2 pages and may be reproduced, as long as it is presented in its entire form, without written permission of Centexbel.
The results of the analysis cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is recognized as notified body 0493 for the European Construction Products directive and the European directive for personal protective equipment

CENTEXBEL GENT
Technologiepark 7
BE-9052 Zwijnaarde (Gent)
Tel. +32 9 220 41 51
Fax +32 9 220 49 55
e-mail gent@centexbel.be

CENTEXBEL BRUSSELS
Montoyerstraat 24-B2
BE-1000 Brussels
Tel. +32 2 287 08 30
Fax +32 2 230 68 15
e-mail brussel@centexbel.be

CENTEXBEL VERVIERS
Avenue du Parc 38
BE-4650 Herve (Chaineux)
Tel. +32 87 32 24 30
Fax +32 87 34 05 18
e-mail chaineux@centexbel.be

VAT BE 0459 218 289 - Fin. Acc. 210-0472965-45 - IBAN BE44 2100 4729 6545
www.centexbel.be